



Embraco Slovakia s.r.o.
Adress : Odorinska Cesta, 2
052 01 Spisska Nova Ves
Tél : ++421 53 4172111
Fax : ++421 53 4412281

DECLARATION

The manufacturer : EMBRACO SLOVAKIA s.r.o.

hereby declares that :

According to paragraph 3.6 of article 1 of the Pressure Equipment (PED), no.97/23/EC of 29 May 1997, the following motor compressors series manufactured under both "ASPERA" or "EMBRACO" trademark, using indicated refrigerating fluids (*):

Series	Refrigerant Fluid
NB, NBM, NBK, NBT, NBU, NBY	R600a, R290, R134a, R22, R404A, R407C, R507
NE, NEK	R600a, R290, R134a, R22, R404A, R407C, R507
T, NT	R290, R134a, R22, R404A, R407C, R507
J, NJ	R134a, R22, R404A, R407C, R507

are excluded from the scope of the PED as they are classified no higher than category I under Article 9 of the PED, and as they are covered by the Council Directive 73/23/EEC of 19 February 1973 commonly named Low Voltage Directive (LVD).

Signed by: Carlos A. Xavier 

Title.....: General Manager

Date.....: 31 / 10 / 2007

(*) Ref.: ASERCOM Statement rev. 7/04/2000 and Bureau Veritas Technical Appraisal Reference PED-TA-ASE-001-00-DEU for "Asercom Statement Rev.08 June 2000 for Refrigerating motor-compressors classified no higher than category I according to the Directive 97/23/EC"



Embraco Slovakia s.r.o.
Adress : Odorinska Cesta, 2
052 01 Spisska Nova Ves
Tél : ++421 53 4172111
Fax : ++421 53 4412281

DECLARATION

The manufacturer : EMBRACO SLOVAKIA s.r.o.

hereby declares that :

According to paragraph 2 of article 3 of the Pressure Equipment (PED), no.97/23/EC of 29 May 1997, the following condensing units series using indicated refrigerating fluids:

Series	Refrigerant Fluid
UNEK, UNT, UNJ, UEM UNB, UNE, UT, UJ	R134a, R22, R12, R404A, R400A, R407C, R507, R600a, R502, R290

does not fall, as an assembly, under the scope of the PED and has not to bear CE marking required by article 1§ 2-1-5 of the PED (*). However we advice that the refrigeration system in which the unit will be part may be considered as an assembly with all the consequences which follow for the manufacturer of the complete system. Upon request we will supply a declaration of conformity and the operating instructions for each component of condensing unit that falls under the scope of PED and which has to bear CE marking. The condensing unit comply with the Council Directive 73/23/EEC of 19 February 1973 commonly named Low Voltage Directive (LVD). Conditions of installation, operation and maintenance must respect requirements of EN 378 – 1 to 4.

Signed by: Carlos A. Xavier 

Title.....: General Manager

Date.....: 31 / 10 / 2007

(*) Ref.: "ASERCOM Statement Rev. 17 December 2001 for Condensing and compressor units"